

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Phoenix Contact GmbH & Co. KG

Flachsmarktstr. 8, 32825 Blomberg, Germany

the Certificate No: **Z12464** for the PROFINET Device:

Model Name: GW PN/ASCII 1E/1DB9

Revision: SW/FW: V1.1.7; HW: 2

Identnumber: 0x00B0; 0x0001

GSD: GSDML-V2.34-PhoenixContact-GWPN1E1DB9-20180528.XML

DAP: PNIO-2101/2201, 0xA0000003

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/> PNIO_Version	V2.33
<input checked="" type="checkbox"/> Conformance Class	B
<input checked="" type="checkbox"/> Optional Features	Legacy, FSU
<input checked="" type="checkbox"/> Netload Class	I
<input checked="" type="checkbox"/> PNIO_Tester_Version	V2.34.0
<input checked="" type="checkbox"/> Tester	PROFI Interface Center, Johnson City, USA; PN018-3 plus Manufacturer Declaration

This certificate is granted according to the document:

"Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by **February 07, 2024** the certificate is valid for life.

Karlsruhe, March 07, 2022



(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.



(Karsten Schneider)



(Dr. Jörg Hähnliche)