

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

SIEMENS AG, DI PA AE HW 4 2

Oestliche Rheinbrueckenstr. 50, 76187 Karlsruhe, Germany

the Certificate No: **Z12655** for the PROFINET Device:

Model Name: Compact Field Unit DIQ (CFU DIQ) V1.2.x
Revision: SW/FW: V1.2.x; HW: 1
Identnumber: 0x002A; 0x060F
GSD: GSDML-V2.35-Siemens-CFU-DIQ-20190417.xml
DAP: CFU DIQ V1.2, 0x0000022F

This certificate confirms that the product has successfully passed the certification tests with the following scope:

☒	PNIO_Version	V2.35
☒	Conformance Class	B
☒	Optional Features	Legacy, MRP, System redundancy S2, Dynamic reconfiguration
☒	Application Class	HighAvailability
☒	Netload Class	II
☒	PNIO_Tester_Version	Version 2.35.2 with annex spirta
☒	Tester	an testlabs, Prague, Czech Republic; PN019-10 plus Manufacturer Declaration

This certificate is granted according to the document:

"Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by **May 20, 2022** the certificate is valid for life.

Karlsruhe, December 05, 2019



(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.



(Karsten Schneider)



(Dr. Jörg Hähnliche)